

ELVIN MCCORVEY MEMORIAL WATER PRODUCTION FACILITY  
FORMERLY WEST WATER TREATMENT FACILITY, BOOSTER STATION AND GAC  
SYSTEM

ECUA PROJECT NUMBER RW819

BID NO. CC2024-02

December 6, 2023

**ADDENDUM NO. 4**

This addendum forms a part of the Contract Documents and modifies the original Specifications dated October 2023, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification. This addendum consists of one (1) page, including all attachments.

Power conductors from each variable frequency drive to the motor terminals shall be VFD rated cables. Cables shall be UL 1277 type TC-ER type XHHW-2, UL approved as 1000 volt flexible motor supply cable. Increase the conduit size from the VFD's to the booster pumps to 3". Increase the conduit size from the VFD to the well pump 3 ½".

End of Addendum