

**ECUA BID NO. 2020 07**  
**TRANSMISSION MAIN INTERRUPTION PLAN COMPONENTS**  
**(April 23, 2020)**

**ADDENDUM NO. 1**

This addendum forms a part of the Bid Documents and changes and/or clarifies the original Bid Document, dated April 2, 2020. This addendum consists of one (1) page.

1. Interior coating (Protecto 401 or Permox) is not required on the ductile iron pipe, fittings, or sleeves. Exterior shop coating requirements remain in effect. These materials are intended to be utilized for temporary bypass only and will not remain as permanent infrastructure.
2. Domestic ductile iron fittings are not required. With the exception of the removal of the interior coating requirement, fittings shall meet or exceed the “ECUA Engineering Manual” specifications.
3. All bolts shall be 316 stainless steel.
4. All fused connections shall be performed by a certified fusion technician of large diameter pipe. A current/up-to-date certification letter provided by the manufacturer of the fusion machine shall be provided to ECUA prior to award.
5. Please note: a new proposal page is incorporated as an attachment to this addendum.

**-END OF ADDENDUM NO. 1-**