

**ECUA BID NO. 2020 07**  
**TRANSMISSION MAIN INTERRUPTION PLAN COMPONENTS**  
**(May 6, 2020)**

**ADDENDUM NO. 2**

This addendum forms a part of the Bid Documents and changes and/or clarifies the original Bid Document, dated April 2, 2020. This addendum consists of one (1) page.

1. Item Number 9 – Mechanical Joint Bolt Kit: The intent for this bolt kit is to connect the fused HDPE MJ Adapter to the Ductile Iron Sleeve. Bidders are to ensure that bolts are of adequate length to make this connection.

**-END OF ADDENDUM NO. 2-**