Emerald Coast Utilities Authority

Water Reclamation

Monthly Report for Sep-2020

Wastewater Treated

Wastewater Facility	Permitted Flow (MGD)	Sep-20 Flow (MGD)	Sep-19 Flow (MGD)	% Change Last Year	3 Month Avg. Flow (MGD)	3 Month Avg. % of Permitted Capacity	12 Month Avg. Flow (MGD)	12 Month Avg. % of Permitted Capacity
Bayou Marcus WRF	8.2	7.58	5.03	50.67%	6.52	79.50%	5.44	66.29%
Pensacola Beach WRF	2.4	1.25	0.89	40.74%	1.21	50.46%	0.89	36.98%
Central WRF	22.5	17.84	13.39	33.23%	15.09	67.07%	13.55	60.21%
Totals:	33.1	26.68	19.31	38.12%	22.82	68.94%	19.87	60.03%

Dry Product Produced	Dry Tons
Produced this Month	382.46
Produced this Fiscal Year	4,084.89
Sold this Fiscal Year	4,084.89

Dry Product Sold	Dry Tons	Rate per Ton	Revenue
Buyer: Greensouth	382.46	$2	$765
Buyer:			
Buyer:			
		Revenue Billed this Fiscal Year:	$8,170

Septage/Grease Received	Gallons
Received this Month	1,186,178
Received this Fiscal Year	14,126,075

Septage/Grease Billed	Gallons	Rate per Thousand Gallons	Revenue
Billed at Regular Rate	1,096,335	$81.00	$88,803
Billed at Premium Rate	89,843	$121.50	$10,916
		Revenue Billed this Fiscal Year:	$1,161,843

Sludge Hauled from Plants

Source	Sep-20 Dry Tons	Fiscal Year Dry Tons
Bayou Marcus WRF	104.16	1,676.97
Pensacola Beach WRF	11.84	229.15
Totals:	116.00	1,906.12

Monthly Summary

Wastewater Treated	26.68	MGD
Sludge Received	116.00	Tons
Dry Product Produced	382.46	Tons
Dryer Product Revenue	$765	
Septage/Grease Received	1,186,178	Gallons
Septage/Grease Revenue	$99,719	

Randy L. Sears, Jr.
Director of Water Reclamation